

DELHI JAL BOARD: GOVT. OF NCT DELHI
OFFICE OF THE EE(RWH)-I
ROOM NO-11, VARUNALAYA PH-I,
JHANDEWALAN NEW DELHI-110005

No.DJB/EE (RWH)-I/2023/1869

Dated:- 05-09-2023

To,

The Manager,
Shri Tula Ram Public School,
D-111/1, Rama Vihar, Mohd.Pur Majri,
Delhi-110081

**Subject: Exemption from Rain Water Harvesting at Shri Tula Ram Public School,
D-111/1, Rama Vihar, Mohd.Pur Majri, Delhi-110081.**

*Reference:- Your Letter dated 30.08.2023 regarding exemption for construction of
RWH System.*

Dear Sir,

With reference to your above mentioned letter for exemption of Rain Water Harvesting at Shri Tula Ram Public School, D-111/1, Rama Vihar, Mohd.Pur Majri, Delhi-110081. The site has been inspected on 05.09.2023 and it has been observed that static ground water level in existing bore well found to be 3.10 m from the existing ground level.

As per DJB guidelines, the Rain Water Harvesting system is not recommended where post monsoon ground water level is shallower than 5.0m. Hence, as per the findings, the Rain Water Harvesting system is exempted from installation at above said premises.

It is also to inform you that in case ground water level is deeper than 5.0m in future, the Rain Water Harvesting System shall have to be installed mandatorily at the above said site as per DJB guidelines.



EE (RWH)-I
Dy. S.E. (RWH)

Delhi Jal Board, Govt. of NCT of Delhi
Varunalaya Phase-I, Karol Bagh
New Delhi-110005